

Water Softener Inspection

"All new or replacement water softeners installed in residential, commercial and public buildings within the village limits shall be DIR "demand-based regeneration." Water softeners functioning only at a predetermined time interval (with a time clock), shall no longer be permitted to be installed in the Village of St. Nazianz. DIR controls meet the "high efficiency softener" standards of the Water Quality Association which are 3,350 grains of hardness removed per one pound of salt. The owner shall have the softener inspected every five years by a plumber or water softener service provider and a copy of the inspection shall be provided to the village clerk-treasurer. Property owners must obtain a building permit for water softener installation and/or replacement of your existing water softener. This will ensure that the village can keep a record of water softeners in the village per DNR requirements." [Ord. No. 2021-02, 7-21-2021](#)

Property Information

Property Owner Name _____

Property Address _____

Owner Contact _____

Phone Number _____

Inspection

- ▶ Softener is Demand-Based Regeneration
☐ Yes ☐ No
- ▶ Meets Water Quality Association Standards - 3,350 grains of hardness removed per 1 # of salt
☐ Yes ☐ No

Signature of Licensed Plumber

Date of Installation/Inspection

Printed Name

License #

Return to:

Village of St Nazianz
228 W Main Street
PO Box 302
St. Nazianz, WI 54232